

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY
CONDITION CERTIFICATE**

No. 1019Date : 26/07/23It is certified that an inspection team headed by Dr. Arun Saini(Name of Officers with designation) from Medical Officer(Name of Department/Office) inspected the AMCO Gautam Buddh NagerName & Address of the School) on 26-07-2023 (Date of Inspection) and found that the N.S.Public School, Jhanjhar Road, Jahangirpur, GautamBudh Nagar (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.The above valid for a period of 01 Year

Signature with Seal: *[Signature]*
 Name : Chief Medical Officer
Gautam Budh Nager
 Designation : _____

To

The PrincipalN.S.Public School, Jhanjhar Road,Jahangirpur, GautamBudh Nagar

(Name & Address of the Institution)

[Signature]
 Manager
 N.S. Public School
 Jhanjhar Road, Jahangirpur (G.B. Nagar)





SHREE RAM TESTING LABORATORIES

NABL (ISO-IEC:17025) Govt. Approved Laboratories

(Dept. of Science & Technology Govt. of India)

Lab-A-2/103, Site – V, UPSIDC Industrial Area, Kasana Greater Nodia

H.O 139/203, Shamon Massion Ajmori Gate, Delhi

Ph-0120-2341275, Mob: 9953984801, 9717160780, E-mail sti.nodia@gmail.com

shreeramlab@yahoo.com, Website : www.shreeramlab.com

Complete Analytical Solution

NABL & ISO 9001-2008 Certified

TEST REPORT

Issued to :N.S. Public School

Report No. W-250623-01

Report Date 27/06/2023

Sample Received on: 25/06/2023

Analysis Date: 25/06/2023 to 27/06/2023

Sampled By: SRTL.

P – 1/1

Ref No.

Sample Description : Drinking Water (R.O. Water)

RESULTS

Drinking Water – Essential Tests as per IS 10500:12

S.N.	Parameters (Units)	Test Method	Results	Requirement as per IS: 10500-2012
1	Odour	IS:3025(P-5) 1983	Unobjectionable	Unobjectionable
2	Taste	IS:3025(P-8) 1984	Agreeable	Agreeable
3	Colour (Hazen)	IS:3025(P-4) 1983	<1.0	5 max
4	Turbidity (NTU)	IS:3025(P-10) 1984	<1.0	5 max
5	pH value (at 25°C)	IS:3025(P-11) 1983	7.35	6.5 to 8.5
6	Total Dissolved Solids (mg/l)	IS:3025(P-16) 1984	130	500 max
7	Total Hardness (as CaCO ₃) (mg/l)	IS:3025(P-21) 1983	91	300 max
8	Chloride (as CL) (mg/l)	IS:3025(P-32) 1988	36	250 max
9	Iron (as Fe)	IS:3025(P-32) 1964	<0.05	0.3 max
10	Residual Free Chlorine (mg/l)	IS:3025(P-26) 1986	Nil	0.20 max
11	Fluoride (as F) (mg/l)	Apha 4500 (D)	Nil	1.0 max
12	MICROBIOLOGICAL PARAMETERS			
(i)	Coliform (per 100ml)	IS:1622 : 1996	Absent	0 max
(ii)	E.Coli (per 100ml)	IS:1622 : 1996	Absent	0 max

Remarks: The tested parameters meet as per BIS specification & suitable for drinking purpose.

END OF REPORT


Manager
N.S. Public School
Jhanjhar Road, Jhansipur (G.B. Nagar)

AUTHORIZED SIGNATORY


